

NUTEK SYSTEMS, LTD.

Unit B, 13/F., Block A, Universal Ind. Ctr., 23-25 Shan Mei Street, Fo Tan, Shatin, N.T., Hong Kong Tel: (852) 2605 5736 Fax: (852) 2692 0798 E-mail: nutek@nuteksystems.com

TITLE : Testing of Puddle Flange

OUR REFERENCE : J 18942

DESCRIPTION OF SAMPLE : 50mm(2") Cast iron tank connector (puddle flange) with screw ends;

pressure rating PN16

SAMPLE SUBMITTED BY : Wah Hung Fire Prevention Equipment Co., Ltd

Unit 14, 9/F Tonic Industrial Centre, Blk A, No.26, Kai Cheung Road, Kowloon Bay, Kowloon, Hong Kong

MANUFACTURER : Wah Nan Fire Fighting Equipment Co., Ltd

BRAND : Wah Hung

ITEM NO. : WH026

MODEL : CIF-5024A

COUNTRY OF ORIGIN : China

BODY MARKINGS : W DN50X600 PN16 BS143&1256


TESTS REQUIRED : 1) BS143&1256: 2000 and

2) Hydrostatic pressure test

PERIOD OF TESTS : 7th Jul., 2015

<u>RESULTS:</u> - (apply only to the samples tested)

1. DIMENSIONS (all dimensions are in millimetres)



		Sample	Requirement
Nominal size		50	/
Overall length		612	
Body tube outside diameter, max.		63.3	/
Diameter of middle flange	D1	120	/
Thickness of middle flange	T2	11.1	/

Note: The female threads at each opening of the sample comply with BS21.

2. HYDRAULIC PRESSURE TEST

	Test pressure (bar)	Duration (s)	Remark
Sample	24	60	Pass

Note: No leakage was detected during the above test.



Tel: (852) 2605 5736 Fax: (852) 2692 0798 E-mail: nutek@nuteksystems.com

OUR REFERENCE NO.J18942 (P.2)

3. SUMMARY OF RESULTS (apply only to the sample tested)

Dimensions

- Satisfactory

Hydraulic pressure test

- Satisfactory

8App. 3016 Authorized signature :

WONG K.S., Sunny

(Director)

a testing agency, approved by the Water Authority and Government Supplies Department, for testing water supply fittings.